CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0067:222 Page 1 of 2

CATEGORY: Control Unit (Non High Rise)

LISTEE: Siemens Building Technologies Inc., *Fire Safety Div., 8 Fernwood Rd, Florham Park NJ 07932

Contact: Peter Pawchak (973) 593-2662 Fax (973) 593-6652

DESIGN: Model "Firefinder" XLS fire alarm control unit. Local, auxiliary, remote station (protected

premises), proprietary, central station (protected premises), waterflow and sprinkler supervisory service. Refer to listee's data sheet and control unit's installation instructions

for additional detailed product description and operational considerations. System

components:

PMI Person Machine Interface

PSC-12 Power Supply

PTB Power Termination Board RPM Remote Printer Interface

CRC-6 Relay Card CC-2, -5 Card Cage

ZIC-4A Zone Indicating Card
DLC Device Loop Card
HTSW-1 Tamper Switch

NIC-C Network Interface Card 5128, 5129 Silent Knight Dialer/DACT

LLM-1 Line Module

FCM-6 Fan Control Module SCM-8 Switch Control Module LCM-8 LED Control Module **CAN Sounder Board** CSB PSX-12 Extender Power Supply SIM-16 Supervised Input Module **OCM-16** Output Control Module RNI Remote Network Interface

HTRI-M , -S, -D, -R Addressable Monitor Module

Enclosure

Mounting Plate

Enclosure Door

Enclosure Door

CAB2-BB, CAB3-BB CAB-MP

CAB2-BD, -RD, -XBD CAB3-BD, -RD, -XBD

CAB1-TK, CAB1R-TK, CAB2-TK, Enclosure Trim Kit CAB2R-TK, CAB3-TK, CAB3R-TK Enclosure Trim Kit

CAB-BATT Battery Box

REMBOX2, -4 Remote System Enclosure

REMBOX2-MP

REMBOX4-MP

Mounting Plate

Mounti

OD-LP, -BP, -GP
ID-SP, -FP
CAB1, CAB1R
BP-61, BTX-1, BTX-2, BTX-3
Door plate
Cabinet
Battery Sets

HLIM Loop Isolator Module

REL-EOL, EL-33 Resistor Kits

*Rev. 10-26-2002

*Rev. 10-26-2002 BH

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed in stallation instructions, NFPA 72, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, or Siemens, model number, rating and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed compatible initiating and

indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Strobe devices can be controlled by the ZIC-4A for (synchronized or unsynchronized) operation.

Refer to manufacturer's Installation Manual for details.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: OCTOBER 26, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager